

Addendum II

RE-BID 26-5120-01 Fire Panel Upgrade Questions & Answers

1. Copy of last inspection report? **YES, PLEASE SEE ATTACHED.**
2. Is there a copy of as-built drawings and program from Metroplex Control Systems for the EST fire alarm system? (they were the company who originally installed the FA System) **CAN EMAIL THEM. FOR THE VENDORS WHO DID NOT ASK THIS QUESTION AND ARE NEEDING IT PLEASE SEND A SEPARATE EMAIL FOR THE REQUEST.**
3. Are we to replace all fire alarm devices on this project, or just the panel head end and remote annunciator components and programming? **IF WILL WORK WITH THE OTHER ITEMS THEN THIS IS ACCEPTABLE**
(the new EST4 system is backward compatible for field devices)
4. Can we reuse existing wires? **YES, BUT REPALCE AS NEEDED**
5. Based on the site walk, there currently is an Alarm/Trouble on the panel. This will be excluded in the scope of work based on lack of information to correct the issue. **SMOKE HEAD ISSUE I1517**
6. How is the PLC-Lock Interface connected to the fire alarm system? If none, please indicate "none" in reply. **NONE**
7. How many Duct Detectors are tied to the existing fire alarm system? **15 I THINK, SEE PLANS BY EMAIL REQUEST. FOR THE VENDORS WHO DID NOT ASK THIS QUESTION AND ARE NEEDING IT PLEASE SEND A SEPARATE EMAIL FOR THE REQUEST.**
8. How are HVAC units shutdown? **RELAY**
 - a. Relay from each duct detector?
 - b. Or, input to the Energy Management System?
9. Please indicate working Hours and access to cell blocks? **ANY**
10. HUB Subcontracting Plan: I see your HUB Policy, but I do not see if a HSP submission is a bid requirement or not. Please advise. **Yes it is required.**



Inspection Report

Presented To
Burnet County Jail

For
Burnet County Detention Center
900 County Ln
Burnet, TX 78611



This site has been inspected and tested in compliance with applicable standards.

Completed:
Thursday, January 15, 2026

Inspection Status:
Passed

Tested By:
Jon Chelgren
STAR Asset Security
12500 Network Blvd ste 402
San Antonio, TX 78249

Accepted By:
Clinton Milam
Burnet County Jail
900 County Ln
Burnet, TX 78611



Inspection Information

CUSTOMER INFORMATION

Name:	Burnet County Jail	Address:	900 County Ln
City:	Burnet	State:	TX
ZIP:	78611	Phone:	(512) 715-8600

BUILDING INFORMATION

Name:	Burnet County Detention Center	Occupancy Type:	Not determined
Address:	900 County Ln	City:	Burnet
State:	TX	ZIP:	78611
Retransmission Entity Phone:	(512) 715-8600		

COMPANY INFORMATION

Name:	STAR Asset Security	Address:	12500 Network Blvd ste 402
City:	San Antonio	State:	TX
Zip:	78249	License:	ACR-1703885
Email:	info@securethinking.com	Phone:	(877) 801-1616

TESTING SUMMARY

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Control Unit	0	0 (0%)	0 (0%)	0 (0%)
Batteries	0	0 (0%)	0 (0%)	0 (0%)
Communicator	0	0 (0%)	0 (0%)	0 (0%)
Supervising Station Monitoring	0	0 (0%)	0 (0%)	0 (0%)
Annunciator	0	0 (0%)	0 (0%)	0 (0%)
Auxiliary Power Supply	0	0 (0%)	0 (0%)	0 (0%)
Alarm Initiating Device	420	420 (100%)	420 (100%)	0 (0%)
Supervisory Signal Device	5	5 (100%)	5 (100%)	0 (0%)
Auxiliary Device	20	20 (100%)	20 (100%)	0 (0%)
Alarm Notification Appliance	3	3 (100%)	3 (100%)	0 (0%)

Fire Alarm System - NFPA 72 (2013)

This inspection was conducted in accordance with **NFPA 72 Standards** and the codes established by the local Authorities Having Jurisdiction for the site inspected. NFPA 72 provides established guidelines for the testing of fire alarm systems, including fire detection, emergency communication and signaling. Where any discrepancies may occur between acceptable test results and actual performance, our recommendations have been provided for your consideration and approval.

According to Texas law governing fire codes, **Star Asset Security** is mandated by the State of Texas to report any deficiencies found during this inspection to Authorities Having Jurisdiction and/or the local Compliance engine. If you have any questions regarding this report or require additional services. Please contact our Service Team at (877) 801-1616 or info@securethinking.com.

Les Peterson
Account Manager - Fire & Life Safety
O: (877) 801-1616
M: (817) 343-1401


Tanner Smith
Service Coordinator - Fire & Life Safety
O: (877) 801-1616
M: (210) 621-4773

Tested By:



Jon Chelgren
STAR Asset Security
12500 Network Blvd ste 402
San Antonio, TX 78249

Accepted By:



Clinton Milam
Burnet County Jail
900 County Ln
Burnet, TX 78611

Alarm Initiating Device

Location	Specification	Result	Notes
Location SMOKE DET. @ DAYROOM 092 / 030049	Type/Make/Model Smoke Detector / GE Security / SIGA-IS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 111 / 030074	Type/Make/Model Smoke Detector / GE Security / SIGA-IS	Result ● Passed	Number -
Location HEAT DET. @ ADMIN SALLY PORT 045 / 030026	Type/Make/Model Heat Detector / GE Security / SIGA-HRS	Result ● Passed	Number -
Location HEAT DET. @ KITCHEN 295 / 030308	Type/Make/Model Heat Detector / GE Security / SIGA-HRS	Result ● Passed	Number -
Location HEAT DET. @ ADMIN SALLY PORT 045 / 030028	Type/Make/Model Heat Detector / GE Security / SIGA-HRS	Result ● Passed	Number -
Location HEAT DET. @ KITCHEN 295 / 030312	Type/Make/Model Heat Detector / GE Security / SIGA-HRS	Result ● Passed	Number -
Location HEAT DET. @ KITCHEN 295 / 030309	Type/Make/Model Heat Detector / GE Security / SIGA-HRS	Result ● Passed	Number -
Location HEAT DET. @ KITCHEN 295 / 030311	Type/Make/Model Heat Detector / GE Security / SIGA-HRS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 138 / 040029	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location AHU-13 DUCT DET. RETURN AIR / 030098	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 182 / 040330	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 156 / 040058	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY S.V. 176 / 040087	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 148 / 040045	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 183 / 040329	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 161 / 040070	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ CORRIDOR158 / 040043	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 165 / 040067	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 179 / 040337	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR184 / 040316	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 179 / 040338	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 179 / 040336	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 174 / 040084	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 189 / 040321	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR184 / 040322	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 182 / 040332	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 161 / 040071	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 191 / 040317	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR 234 BY CORR 194 / 040040	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 163 / 040068	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR274 / 030328	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR267 / 030301	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ CONTROL CORR. BY P.C. 210 / 040288	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 161 / 040073	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR 234 BY CORR 133 / 040006	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ STAFF RESTROOM 192 / 040315	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ INMATE VISET 017 / 030325	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PUBLIC LOBBY 002 / 030322	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 161 / 040072	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY P.C. 146 / 040290	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 171 / 040077	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 148 / 040044	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ LAUNDRY LINEN STORAGE 266 / 030300	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 188 / 040325	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ INMATE VISET 019 / 030318	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 175 / 040086	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR261 / 030287	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 172 / 040081	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 24 MAN DORM 188 / 040323	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR261 / 030294	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR287 / 030305	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 268 RESTROOM / 030290	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 188 / 040324	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN CORRIDOR 010 / 030001	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ TRAINING ROOM STORAGE ROOM / 030289	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR261 / 030296	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PUBLIC VISET 020 / 030319	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ LAUNDRY 263 / 030298	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR158 / 040060	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 171 / 040080	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 268 / 030293	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR267 / 030297	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 177 / 040339	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 191 / 040319	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ SECURE VESTIBULE 290 / 030304	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 150 / 040074	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 149 / 040047	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 154 / 040059	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 165 / 040064	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 268 RESTROOM / 030291	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ INMATE VISET 021 / 030326	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 186 / 040328	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 171 / 040079	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 174 / 040085	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ LAUNDRY 263 / 030299	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR278 / 030330	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL ROOM 279 / 030329	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR167 / 040076	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR158 / 040061	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 24 MAN DORM 191 / 040318	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 137 / 040027	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 165 / 040066	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CLASSROOM 272 / 030288	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY CORR. 184 / 040314	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR167 / 040063	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR167 / 040069	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 171 / 040078	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 174 / 040083	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR184 / 040327	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 180 / 040334	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 182 / 040331	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN CORRIDOR 010 / 030002	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PUBLIC VISET 020 / 030320	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY P.C. 120 / 040251	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 191 / 040320	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 24 MAN DORM 182 / 040333	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 188 / 040326	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 174 / 040082	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR022 / 030327	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ VESTIBULE 015 / 030324	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SECURE VESTIBULE 018 / 030321	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 179 / 040335	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 147 / 040042	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PUBLIC LOBBY 002 / 030323	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ COMMUNICATIONS RM 273 / 030332	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 165 / 040065	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 166 / 040062	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL UTILITY 054 / 030036	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 097 / 030052	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR CORRIDOR M101 / 020032	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ PLUMBINGCHASE 062 / 030085	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL CORRIDOR 059 / 030038	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M132 / 020010	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 124 / 040009	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 135 / 040022	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 213 / 040280	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 074 / 030062	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 294 / 030315	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 128 / 040018	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 252 / 030275	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M124 / 020039	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR116 / 030080	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 125 / 040011	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 122 / 040004	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 216 / 040272	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 125 / 040012	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 8 MAN M.O. CELL 216 / 040273	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 138 / 040028	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 128 / 040017	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 120 / 040001	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 215 / 040274	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 112 / 030073	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ KITCHEN RESTROOM 296 / 030310	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M108 / 020023	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M146 / 020009	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 077 / 030060	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M109 / 020024	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 141 / 040035	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 140 / 040033	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 124 / 040010	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 294 / 030314	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ STORAGE ROOM 118 / 030083	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ PLUMBINGCHASE 121 / 040002	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 141 / 040034	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 135 / 040023	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 294 / 030316	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR133 / 040021	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PROGRAM ROOM 119 / 030084	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 136 / 040025	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR116 / 030079	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 139 / 040031	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 250 / 030273	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 123 / 040007	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 103 / 030081	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 214 / 040277	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 140 / 040036	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 127 / 040015	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 115 / 030078	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 8 MAN M.O. CELL 122 / 040005	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MECHANICAL ROOM 117 / 030082	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 214 / 040276	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 294 / 030313	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 215 / 040275	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 237 / 030253	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 136 / 040026	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR133 / 040003	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR CORRIDOR M101 / 020028	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 236 / 030255	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SECURITY ELECTRONICS / 020002	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M128 / 020036	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 105 / 030069	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 086 / 030055	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 256 / 030279	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ PLUMBINGCHASE 129 / 040019	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE ROOM 259 / 030285	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 237 / 030256	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 260 / 030283	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 134 / 040020	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 139 / 040030	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 115 / 030077	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 123 / 040008	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 127 / 040014	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location HEAT DET. @ CORRIDOR293 / 030306	Type/Make/Model Heat Detector / EST / SIGA- HRS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 238 / 030261	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 085 / 030056	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 243 / 030271	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M145 / 020008	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ PLUMBINGCHASE 260 / 030284	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR247 / 030259	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 072 / 030063	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 108 / 030066	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR CORRIDOR M101 / 020029	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 094 / 030050	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 099 / 030053	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ DAYROOM 081 / 030058	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 238 / 030260	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR247 / 030258	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 107 / 030067	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 241 / 030267	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MULTI- PURPOSE 268 / 030292	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M121 / 020033	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 242 / 030269	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M112 / 020048	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ M.O. CELL 241 / 030268	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M103 / 020020	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M141 / 020004	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M143 / 020006	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M122 / 020040	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M112 / 020041	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M120 / 020046	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SECURITY ELECTRONICS / 020001	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR247 / 030257	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 075 / 030061	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 254 / 030277	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY CORR. 116 / 030252	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @HANDY CAPSEPERATION CELL 249 / 030272	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M106 / 020022	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 169 / 040075	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ M.O. CELL 239 / 030262	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 083 / 030057	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 212 / 040282	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 239 / 030263	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 245 / 030282	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 131 / 040039	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 253 / 030276	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 096 / 030051	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M121 / 020034	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 251 / 030274	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ JANITOR'S CLOSET 292 / 030307	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 106 / 030068	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 149 / 040046	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M112 / 020047	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY CORR. 247 / 030254	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CONTROL CORR. BY CORR. 261 / 030286	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 2ND FLR SINGLE CELL M130 / 020035	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 240 / 030265	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M114 / 020042	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 114 / 030071	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M115 / 020043	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M105 / 020021	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SINGLE CELL 088 / 030054	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M111 / 020025	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ M.O. CELL 240 / 030264	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 212 / 040281	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ DAYROOM 079 / 030059	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M118 / 020045	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M125 / 020038	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M117 / 020044	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ STAFF TOILET 258 / 030281	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR100 / 030064	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 255 / 030278	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ M.O. CELL 242 / 030270	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SINGLE CELL M127 / 020037	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ H.C. SEPERATION CELL 110 / 030075	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR100 / 030065	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M102 / 020026	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M144 / 020007	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M132 / 020011	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR MEZZANINE M102 / 020027	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL CLEAN LINEN 053 / 030035	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 197 / 040308	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 203 / 040295	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 151 / 040052	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR133 / 040038	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL WARD 068 / 030041	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 211 / 040284	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 219 / 040286	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ ADMIN SECURITY VESTI. 038 / 030010	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR274 / 030331	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN PLUMBING CHASE 041 / 030023	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 233 / 040253	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN CORRIDOR 023 / 030018	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 225 / 040265	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 232 / 040255	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 232 / 040256	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 208 / 040289	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 230 / 040260	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR221 / 040261	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 203 / 040294	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN HOLDING CELL 035 / 030007	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR228 / 040258	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 153 / 040056	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 24 MAN DORM 232 / 040257	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 213 / 040279	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN DETOX. CELL 043 / 030015	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR194 / 040310	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR221 / 040254	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 201 / 040299	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 202 / 040298	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR221 / 040271	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 227 / 040264	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 152 / 040054	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL JANITOR'S CLOSET 069 / 030039	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN MAGISTRATE 024 / 030019	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR194 / 040293	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN PROCESSING 030 / 030014	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN VIOLENT CELL 028 / 030016	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 150 / 040049	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 8 MAN M.O. CELL 151 / 040051	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL RESTROOM 056 / 030030	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 225 / 040266	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR100 / 030076	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ JANITORS COLSET 257 / 030280	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN CORRIDOR 049 / 030043	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL PLUMBING CHASE 070 / 030040	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 24 MAN DORM 232 / 040259	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN PROCESSING 030 / 030004	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M137 / 020013	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN GUARD STATION 029 / 030003	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 126 / 040013	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M136 / 020014	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL WARD 071 / 030037	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL WAIT / TRAGE 055 / 030031	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ ADMIN PROPERTY & ISSUE 044 / 030022	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 198 / 040304	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 224 / 040268	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL ISOLATION CELL 061 / 030044	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 152 / 040016	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 217 / 040270	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN PROPERTY & ISSUE 044 / 030025	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL ISOLATION CELL 063 / 030045	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN CORRIDOR 049 / 030021	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL EXAM ROOM 051 / 030033	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 202 / 040297	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN INTOX. CELL 039 / 030011	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN HOLDING CELL 033 / 030006	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 207 / 040292	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ PLUMBINGCHASE 196 / 040309	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL CORRIDOR 060 / 030042	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 223 / 040269	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN CORRIDOR 049 / 030029	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M133 / 020017	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN DRESS CELL 040 / 030024	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL JANITOR'S CLOSET 066 / 030047	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN INTERVIEW 025 / 030017	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 224 / 040267	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN RECORDS 036 / 030009	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR194 / 040312	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 210 / 040287	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN PROCESSING 030 / 030012	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 200 / 040301	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN DETOX. CELL 042 / 030013	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ ADMIN HOLDING CELL 032 / 030005	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 150 / 040050	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 197 / 040307	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M135 / 020015	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL STORAGE 067 / 030048	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 198 / 040305	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M134 / 020016	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 153 / 040055	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 201 / 040300	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M138 / 020012	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL SOILED LINEN 052 / 030034	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ADMIN MECHANICAL ROOM 027 / 030020	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 146 / 040041	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL PLUMBING CHASE 065 / 030046	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 227 / 040263	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Location	Specification	Result	Notes
Location SMOKE DET. @ 8 MAN M.O. CELL 211 / 040283	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MEDICAL EXAM ROOM 050 / 030032	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 226 / 030266	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 250 / 030251	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ PLUMBINGCHASE 199 / 040303	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 143 / 040037	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ CORRIDOR287 / 030317	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ELECTRICAL ROOM 289 / 030086	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ ELECTRICAL ROOM 289 / 030087	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SALLY PORT MAINTENANCE STG. / 030027	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ GUARD STATION 205 / 040311	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ MECHANICAL ROOM 288 / 030302	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location AHU-14 DUCT DET. RETURN AIR / 030333	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-11 DUCT DET. RETURN AIR / 030096	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-15 DUCT DET. RETURN AIR / 030094	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -

Location	Specification	Result	Notes
Location AHU-12 DUCT DET. RETURN AIR / 030097	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-02 DUCT DET. RETURN AIR / 030089	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-08 DUCT DET. RETURN AIR / 030095	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-04 DUCT DET. RETURN AIR / 030091	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-10 DUCT DET. RETURN AIR / 030334	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-06 DUCT DET. RETURN AIR / 030093	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-03 DUCT DET. RETURN AIR / 030090	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-07 DUCT DET. RETURN AIR / 030100	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-01 DUCT DET. RETURN AIR / 030088	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-09 DUCT DET. RETURN AIR / 030333	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location AHU-05 DUCT DET. RETURN AIR / 030092	Type/Make/Model Duct Smoke Detector	Result ● Passed	Number -
Location SMOKE DET. @ 2ND FLR SEPERATION CELL M142 / 020005	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ 8 MAN M.O. CELL 200 / 040302	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location SMOKE DET. @ SEPERATION CELL 113 / 030072	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -
Location KITCHEN ANSUL HOOD SYSTEM 1 / 030387	Type/Make/Model GE Security / SIGA-CT1	Result ● Passed	Number -
Location KITCHEN ANSUL HOOD SYSTEM 2 / 030388	Type/Make/Model GE Security / SIGA-CT1	Result ● Passed	Number -

Location	Specification	Result	Notes
Location PULL @ GARD STATION 245 / 030377	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 178 / 040134	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ DOCK 298 / 030380	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 168 / 040132	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SALLY PORT / 030127	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 180 / 040383	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SALLY PORT MAINTENANCE STORAGE / 030150	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 131 / 040128	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 159 / 040130	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 219 / 040378	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 108 / 030130	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ ADMIN GUARD STATION 029 / 030126	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ CONTROL ROOM 279 / 030382	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SALLY PORT / 030129	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 205 / 040380	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ PUBLIC LOBBY 002 / 030381	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -

Location	Specification	Result	Notes
Location PULL @ GARD STATION 163 / 040131	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 230 / 040376	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 222 / 040377	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 100A / 020129	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 156 / 040129	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 185 / 040382	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SALLY PORT MAINTENANCE OFFICE / 030128	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 288 / 030379	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 189 / 040381	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 172 / 040133	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 195 / 040379	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 264 / 030378	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 252 / 030376	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ GARD STATION 143 / 040127	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location PULL @ SECURE VESTIBULE 133A / 040126	Type/Make/Model Manual Pull Station / GE Security / SIGA-278	Result ● Passed	Number -
Location Smoke Detector Sep Cell 1 / 030008	Type/Make/Model Smoke Detector / GE Security / SIGA-PS	Result ● Passed	Number -

Supervisory Signal Device

Location	Specification	Result	Notes
Location 24 VOLT POWER BPS @ SECURITY ELECT. M139 / 020130	Type/Make/Model Monitor Module / GE Security / SIGA-CT1	Result ● Passed	Number -
Location RISER 2 @ MECHANICAL ROOM 288 / 030385	Type/Make/Model Water Flow / GE Security / SIGA-CT2	Result ● Passed	Number -
Location RISER 2 @ MECHANICAL ROOM 288 / 030386	Type/Make/Model Monitor Module / GE Security / SIGA-CT2	Result ● Passed	Number -
Location RISER 1 @ MECHANICAL ROOM 288 / 030383	Type/Make/Model Water Flow / GE Security / SIGA-CT2	Result ● Passed	Number -
Location RISER 1 @ MECHANICAL ROOM 288 / 030384	Type/Make/Model Monitor Module / GE Security / SIGA-CT2	Result ● Passed	Number -

Auxiliary Device

Location	Specification	Result	Notes
Location ZONE 04 SMOKE PURGE RELAY / 030134	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 02 SMOKE PURGE RELAY / 030132	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 03 DAMPER CONTROL / 030143	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 02 DAMPER CONTROL / 030142	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 06 SMOKE PURGE RELAY / 030136	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 01 SMOKE PURGE RELAY / 030131	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 08 SMOKE PURGE RELAY / 030138	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 03 SMOKE PURGE RELAY / 030133	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 08 DAMPER CONTROL / 030148	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -

Location	Specification	Result	Notes
Location ZONE 06 DAMPER CONTROL / 030146	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location AHU 10 DAMPER CONTROL / 030389	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 10 SMOKE PURGE RELAY / 030140	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 10 DAMPER CONTROL / 030149	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 07 SMOKE PURGE RELAY / 030137	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 01 DAMPER CONTROL / 030141	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 04 DAMPER CONTROL / 030144	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 09 SMOKE PURGE RELAY / 030139	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 05 DAMPER CONTROL / 030145	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 07 DAMPER CONTROL / 030147	Type/Make/Model Fire Smoke Damper Control / GE Security / SIGA-CR	Result ● Passed	Number -
Location ZONE 05 SMOKE PURGE RELAY / 030135	Type/Make/Model Fan Shut Down Relay / GE Security / SIGA-CR	Result ● Passed	Number -

Alarm Notification Appliance

Location	Specification	Result	Notes
Location BPS-B @ 2ND FLR SECURITY ELECT. M139 / 020127	Type/Make/Model Other / GE Security / SIGA-CC1S	Result ● Passed	Number -
Location BPS-A @ 2ND FLR SECURITY ELECT. M139 / 020126	Type/Make/Model Other / GE Security / SIGA-CC1S	Result ● Passed	Number -
Location BPS-C @ 2ND FLR SECURITY ELECT. M139 / 020128	Type/Make/Model Other / GE Security / SIGA-CC1S	Result ● Passed	Number -

Comments

Number	COMMENT	IMAGE
1	ANSUL and sprinkler tested by others.	



Conclusion

Thank you for trusting **Star Asset Security** to provide the **NFPA 72 (2013) Fire Alarm Inspection** for your site. Please see the attached report for detailed information on your system, each device inspected, its "Pass or Fail" status, and any applicable comments or recommendations. All of the inspection information has been stored on our secure servers and is also available to you via the QR code included in this report. If you have any questions regarding our findings, please contact us.

Star Asset Security, a Pavion company, is a world-class, performance-based, risk, resilience, and security services firm that thinks globally and acts locally, to ensure the protection of people, assets, and the business goals of our clients. We provide additional services for government and businesses.

- Managed IT, cyber security and physical security services
- Design, installation and service of IT, security, fire and life safety systems
- 24/7 Professional monitoring

For more information on any of our services, please visit us online at securethinking.com. We appreciate your business and look forward to serving you again.

Les Peterson
Account Manager - Fire & Life Safety
O: (877) 801-1616
M: (817) 343-1401

Tanner Smith
Service Coordinator - Fire & Life Safety
O: (877) 801-1616
M: (210) 621-4773

Tested By:
Jon Chelgren
STAR Asset Security
12500 Network Blvd ste 402
San Antonio, TX 78249

Accepted By:
Clinton Milam
Burnet County Jail
900 County Ln
Burnet, TX 78611